

ADDENDUM #4

FC Dental Suite Alterations, FB2758

BIDS WILL BE OPENED ON
2:00 PM, October 7, 2026

AT

City Hall Building, 101 North Main Street, Winston-Salem, North Carolina
Conference Room 16

October 2, 2026

**Proposers are to acknowledge receipt of this Addendum with this signature page and
MUST include it with their proposal.**

Catherine Knisley
Construction Specialist

Company

Authorized Signature

Date

BID CLARIFICATIONS

See attached clarifications or changes, which are hereby made to the bid specifications and requirements:

- Please see attached revised plumbing fixture.



CONSULTANT ENGINEERING SERVICE, INC.

PLUMBING ▪ MECHANICAL ▪ ELECTRICAL

Phone: 336.724.0139 ▪ 1111 S Marshall Street, Suite 250, Winston Salem, NC 27101

Forsyth County Health Department – Dental Suite Alteration

Addendum

PLUMBING - FIXTURE SCHEDULE

P001 – PLUMBING FIXTURE SCHEDULE:

Revise the Plumbing Fixture Schedule on Sheet P001, SK2, as follows:

SINK: ELKAY ECTRUAD301755, 31-1/2" × 18-1/2" × 5-1/2", 18 GA. STAINLESS STEEL, SINGLE BOWL, UNDERMOUNT, ADA COMPLIANT.

FAUCET: ZURN Z2671C4-XL-21F-HCT, 4" CENTRESET DECK-MOUNT FAUCET.

FAUCET MOUNTING: PROVIDE FAUCET MOUNTED THROUGH COUNTERTOP. COORDINATE COUNTERTOP FABRICATION FOR 4" CENTRESET FAUCET HOLES.

ALL OTHER REQUIREMENTS AND CONNECTIONS SHALL REMAIN AS INDICATED ON THE CONTRACT DOCUMENTS.

